



Prüfzentrum für Bauelemente

Dipl.-Ing. (FH) Rüdiger Müller

Fenster • windows
 Rollläden • shutters
 Türen + Tore • doors
 Fassaden • curtain walling
 Baubeschläge • building hardware

TEST CERTIFICATE NO. 13/07-A259-Z1

Version 1.en

Initial type testing (ITT) of performance characteristics in accordance with EN 14351-1 :2006 + A1 : 2010 “Windows and doors - Product standard, performance characteristics - Part 1: Windows and external pedestrian doorsets without resistance to fire and/or smoke leakage characteristics – German version EN 14351-1:2006 + A1:2010”

Applicant Ankara Çelik Kapı San. Ve Tic. Ltd. Şti.
 Alinteri Bulvarı No: 212
 06374 Ostim / Ankara

Product type Single wing steal door with wood cover




Product name ACK Kaprof Kroma (14 bolts)

Closing condition Closed and locked

Dimension Total outside dimensions (W x H) max. 2077 mm x 1096 mm
 Wing dimension (WxH) max. 952 mm x 1992 mm

Classification According to test report No. 13/07-A259-B1 from April 22, 2014:



	EN 1026	Air Permeability	EN 12207	Class 1
	EN 1027	Water Tightness	EN 12208	Class 1
	EN 12211	Resistance to Wind Load	EN 12210	Class C5/B5

Validity Period of validity of EN 14351-1 : 2006 + A1 : 2010

Matthias Demmel

Dipl. Ing. Matthias Demmel
 Head of Notified Test Body



Stephanskirchen
 April 22, 2014

Christoph Geiger

Dipl.-Ing. (FH) Christoph Geiger
 Responsible Official

PfB GmbH & Co. Prüfzentrum für Bauelemente KG
 AG Traunstein HRA 8871
 Lackermannweg 24, 83071 Stephanskirchen
 phG PfB Verwaltungs GmbH
 Geschäftsführer: Matthias Demmel, Rüdiger Müller
 AG Traunstein HRB 16490

Telefon +49 (0) 80 36 / 67 49 47 0
 Telefax +49 (0) 80 36 / 67 49 47 28
 www.pfb-rosenheim.de
 info@pfb-rosenheim.de

Sparkasse Rosenheim
 Bankleitzahl 711 500 00
 Kontonummer 500 556 741
 Steuer-Nr.156/172/13009
 USt-IdNr. DE245353602

